



REQUEST FOR TENDERS #22-06
Golden Age Apts Emergency Generator Upgrade

Addendum No. 2
Tuesday, May 31, 2022

NOTICE TO ALL POTENTIAL BIDDERS

The following addendum shall be part and parcel of the tendering document and shall supersede the drawings and/or specifications where applicable. Upon receipt of same, staple it directly to the inside front cover of the specifications.

General

1. A temporary generator is not required for the duration of the project but the existing emergency loads must remain energized for the duration of the project.
2. The circuit for auxiliary genset power shall be fed from panel ED2B.
3. Refer to duct bank detail 3/ME101 and floor plan detail 2/ME103. The spare 63mmC is not shown on the floor plan. This should be stubbed up at floor level and capped. An extra 53mmC appears on the floor plan. This is for ATS controls to the second ATS.

A handwritten signature in black ink, appearing to read 'Ryan MacVicar', written over a light grey rectangular background.

Ryan MacVicar, P.Eng.

End of Addendum No. 2